



**UST Inspection In Compliance Letter
UST Program**

_____ Owner _____ Date

_____ Address

RE: Underground Storage Tank (UST) Compliance Inspection

_____ Facility name, facility ID#

_____ Address

Dear _____:

On _____, I conducted a routine UST compliance inspection at this facility. The UST systems and the leak detection methods and records were in compliance with the requirements of the South Carolina Underground Storage Tank Control Regulations.

Thank you,

UST Field Staff

cc: UST Program, Regulatory File
2600 Bull Street
Columbia, SC 29201
803-896-7957
Fax: 803-896-6245

Important Test Dates for your Site:

Cathodic Protection System test (3 years) Due Date _____

Line Leak Detector Function Check (annual) Due Date _____

Sump Sensor Function Check (annual) Due Date _____

Line Tightness Test (annual/3 years) Due Date _____

Tank Tightness Test (annual/5 years) Due Date _____